

Capstone Low Emissions MicroTurbine Technology

White Paper
July 19, 2000



Capstone Turbine Corporation
21211 Nordhoff Street, Chatsworth, CA 91311
Phone (818) 734-5300, www.capstoneturbine.com

Capstone Low Emissions MicroTurbine Technology

Table of Contents

1. INTRODUCTION.....	4
2. CRITICAL POLLUTANTS.....	4
3. CAPSTONE’S LOW EMISSIONS COMBUSTION PROCESS.....	5
4. HOW THE CAPSTONE MICROTURBINE’S EMISSIONS COMPARES TO OTHERS SYSTEMS.....	6
4.1 COMPARED TO OTHER TURBINES	6
4.2 COMPARED TO INTERNAL COMBUSTION ENGINES	7
4.3 COMPARED TO THE GRID.....	7
5. GREEN HOUSE GASES.....	8
6. OXYGEN RICH EXHAUST.....	9
7. CURRENT AIR QUALITY REGULATIONS.....	9
7.1 THE U.S. REGULATORY FRAME.....	9
7.2 REGULATION OF STATIONARY SOURCES.....	10
7.3 MOBILE APPLICATIONS.....	13
8. EMISSIONS MEASUREMENT AND TESTING.....	14
9. EMISSIONS CORRECTIONS	15

Preface

The purpose of this White Paper is to provide factual information to Capstone Customers and other Stakeholders about the combustion process employed by the Capstone MicroTurbine[®] and the emissions levels achieved by the technology.

Capstone Low Emissions MicroTurbine Technology

1. Introduction

The Capstone MicroTurbine uses 3 injectors and a sophisticated control system to achieve an emissions profile over a wide range of the power output band that is among the lowest of any fossil fuel combustion technology. While there is a variation in emissions between individual units, Capstone always warrants the NO_x (NO plus NO₂) emissions to be less than 9ppm when its microturbines are fueled with natural gas. CO emissions are less than 40ppm and Total Hydrocarbon (THC) emissions are below 9ppm when natural gas is the fuel source. The Capstone MicroTurbine system's emissions profile is summarized in Table 1 below. Table 1 also provides the emissions levels using a range of different measurement methods.

Table 1. Capstone Microturbine system emission profile

Pollutant	ppmV @ 15% O₂	gm/kw-hr	gm/GJ	gm/hp-hr	lb/kWh	lb/hp-hr
NO _x	9	0.223	61.94	0.166	4.91E-04	3.66E-04
CO	40	0.603	167.56	0.450	13.3E-04	9.90E-04
HC	9	0.078	21.54	0.058	1.71E-04	1.27E-04
NO _x +HC		0.301	83.48	0.224	6.61E-04	4.93E-04

Operating on Natural Gas at full power. Capstone Turbine Corp warrants emissions of NO_x to be less than 9ppm. Other emissions targets are not warranted.

2. Critical Pollutants

Without the use of advanced combustion technologies, natural gas fueled combustion processes can result in the formation of significant amounts of NO₂ and CO. Capstone has focussed on minimizing the formation of these criteria pollutants by developing and

incorporating patented advanced combustion technologies into the Capstone MicroTurbine model 330. Other criteria pollutants are minimal when natural gas is used to fuel a turbine.

Nitric Oxide (NO) is the most significant nitrogen based emission resulting directly from a high temperature combustion processes. NO subsequently oxidizes in the atmosphere to form NO₂, which can have a significant detrimental effect on human wellbeing. In addition, NO and NO₂ (collectively referred to as NO_x) are a precursor to ozone formation, which causes smog and respiratory problems.

CO is a poisonous gas formed when a carbon based fuel is not fully burned. It also contributes to the formation of ozone, albeit, at a lesser rate than NO_x.

Capstone also targets very low emissions of Total Hydrocarbons in its technology. THC's are also a product of incomplete combustion. Emission levels of THC's decrease as combustion temperatures increase. THC's are not a criteria pollutant. However, some reactive Volatile Organic Compounds (VOC), which are a subset of THC's, contribute to smog.

3. Capstone's Low Emissions Combustion Process

Fast and precise control of the combustion process is necessary to achieve Capstone's low overall emissions. NO_x formation diminishes as the combustion temperature declines, but a low combustion temperature result in higher emissions of CO and THC. To resolve this conflict and achieve low NO_x emissions simultaneously with low CO and THC emissions, combustion of the fuel must occur at the lowest possible temperature whilst the air and fuel mix must remain in the combustion chamber long enough to combust most of the fuel

The Capstone MicroTurbine uses a lean-premix combustion system to achieve low emissions levels at the full power range. Lean-premix operation requires operating at a

high air to fuel ratio (AFR) within the primary combustion zone. The large amount of air is thoroughly mixed with the fuel before combustion. This premixing of the air and fuel enables clean combustion to occur at a relatively low temperature. Injectors control the air to fuel ratio and the air-fuel mixture in the primary zone to ensure that the optimal flame temperature is achieved for NO_x minimization.

The higher air to fuel ratio results in a lower flame temperature, which leads to lower NO_x levels. In order to achieve low levels of CO and THC simultaneously with low NO_x levels, the air and fuel mixture is retained in the combustion chamber for a relatively long time period. This process allows for more complete combustion of the CO and THC's.

The NO_x, CO and THC levels are at their lowest when the Capstone MicroTurbine is operating over an output range between 90 per cent and 100 per cent.

4. How the Capstone MicroTurbine's Emissions Compares to Others Systems

4.1 Compared to other turbines

Gas turbine emissions data are commonly corrected to 15% oxygen in the exhaust gases, since they operate in an "excess air" mode. Other combustion sources such as IC engines, boilers, furnaces, etc., may be corrected to 3% or 7% oxygen, or reported uncorrected. For an accurate comparison of emissions between different types of equipment, the emissions should be corrected to the same level of oxygen in the exhaust gases. In addition, the load state during the test (part load or full load operation) should be noted. Table 2 compares data from several turbine and IC engines to the Capstone Model 330 operated at full power¹.

¹ While the load state is shown in the table, the source data did not specify to which level of exhaust oxygen the data were corrected. Therefore these data should be used for rough comparisons only.

Table 2. Comparison of emissions (ppm @ 15% O₂) from Capstone MicroTurbine Model 330 to other stationary combustion sources. Fuel: natural gas.

<u>Technologies</u>	<u>Rating</u>	<u>NOx</u>	<u>CO</u>	<u>THC</u>
Capstone (1)	30 kW	9	40	9
Other MicroTurbines (2)	45 - 75 kW	9 - 25	25-240	25
Industrial Turbines(3)	0.8 - 11 MW	6 -140	1 - 462	6 - 559

(1) Derived from internal Capstone testing, fuelled with Natural Gas

(2) As reported by manufacturers

(3) EPA test results as reported by EPA

4.2 Compared to Internal Combustion Engines

In the absence of a post combustion device such as a catalytic converter, internal combustion engines can have very high emissions levels. Table 3 below summarizes the emissions levels of a broad range of these engines. It indicates that the very best internal combustion engines have emissions of NOx that are significantly higher than the Capstone MicroTurbine. Both CO and THC are much higher for an internal combustion engine than for the Capstone MicroTurbine.

Table 3. Comparison of emissions (ppm @ 15% O₂) from Capstone Model 330 to other stationary Internal combustion sources. Fuel: natural gas.

<u>IC Engine Size</u>	<u>NOx</u>	<u>CO</u>	<u>THC (1)</u>
170kW – 1500kW (3)	30 - 3214	325 - 833	2747
35kW (3)	31-454	244-378	NR
Capstone MicroTurbine (2)	9	40	9


(1) THC data is available only for the 1500kW IC engine.

(2) Fueled with Natural gas

(3) Source: EPA, ICCR

4.3 Compared to the Grid


Capstone’s NOx emissions are very favorable in comparison to grid supplied power. The following graph illustrates this benefit in respect of NOx for which there is reasonable information.



Note: The emissions levels for the grids are not adjusted for distribution and transmission losses, which average 5% - 7%.

5. Green House Gases

CO₂ levels per kWh of electricity produced are affected by fuel type and are directly related to the efficiency of the system. Higher engine efficiencies will result in lower CO₂ levels. The following graph shows that, fueled with Natural Gas, the Capstone MicroTurbine has lower CO₂ emissions than the US national average and has emissions of CO₂ less than all the major US grids.



6. Oxygen Rich Exhaust


The oxygen concentration in the engine exhaust is high (~18.3%), allowing the exhaust to be potentially used in direct heating or as an air pre-heater for downstream burners. This oxygen rich exhaust together with low emissions and air bearings (which allow the turbine to operate without oil lubrication) make the direct exhaust suitable even for certain applications in food processing and green houses.

7. Current Air Quality Regulations

7.1 The U.S. Regulatory Frame.

The Federal government's principal mechanism for controlling air emissions is the Clean Air Act. This Act authorizes the US Environmental Protection Agency (EPA) to set and achieve National Ambient Air Quality Standards (NAAQS) in each state. The EPA sets

ambient air limits for nitrogen dioxide (NO₂), carbon monoxide (CO), sulfur dioxide (SO₂), lead (Pb), ozone (O₃) and particulate matter. These six emissions components are referred to as criteria pollutants. States are required to provide the EPA with a State Implementation Plan which explains how the air quality objectives will be met by each state. The Clean Air Act also requires that the EPA regulate air emissions from mobile sources. The roles and responsibilities of the state and federal agencies in emissions control are detailed in the following chart.




7.2 Regulation of Stationary Sources

There are numerous air quality regulations which impact stationary combustion sources in the US. Despite the number and complexity of these regulations, a conceptual summary is fairly straightforward.

The federal US Clean Air Act (1970) and Clean Air Act Amendments (1990) set concentration limits in ambient air for the six “criteria” pollutants. Urban areas in the US

are categorized according to their level of “attainment” with the National Ambient Air Quality Standards (NAAQS) for these six pollutants. Los Angeles, for example, is currently in “extreme” non-attainment for O₃, and is also out of attainment with respect to CO and NO₂. Current and potential non-attainment areas in the United States are illustrated in the following map.



Pursuant to the Clean Air Act, each local Air District must submit to EPA their plan (State Implementation Plan or SIP) which demonstrates a strategy for controlling emissions, as well as the results of complex 3-dimensional modeling showing that control strategies will reduce ambient pollutants. Typically, the Air Districts adopt Best Available Control Technology (BACT) as the basis for determining permissible emissions levels from new stationary sources of emissions of criteria pollutants. BACT defines the permissible emissions level for each type of emissions source. New stationary sources greater than a defined size are required to meet the (BACT) standard as part of the permitting process. Technologies below the defined size do not require a permit to operate. In general, the Capstone MicroTurbine is below the permitting size threshold. As a result, permitting is not currently required in most situations.

Table 4 is included below to illustrate Capstone’s emissions relative to BACT levels for other technologies. There is no BACT for a microturbine of the size of the Capstone MicroTurbine model 330.

Table 4. Comparison of regulations affecting stationary combustion sources in Southern California Air Quality Management District (SCAQMD).

(ppm)	<u>NO_x</u>	<u>CO</u>	<u>THC</u>	<u>VOC</u>
<i>Capstone MicroTurbine (30 kW) (1)</i>	< 9	< 40	< 9	
<i>Best Available Control Technology</i>				
Gas Turbine (<23 mmbtu/hour)	9	10		
Gas Turbine (landfill gas)	25			
Gas Turbine (> 3MW)	2.5	10		
Combustion Boiler (<16.7mmbtu/hour)	1.64	16.48		

(grams/b-hph)	<u>NO_x</u>	<u>CO</u>	<u>THC</u>	<u>VOC</u>
<i>Capstone MicroTurbine (30 kW) (1)</i>	< 0.166	< 0.450	< 0.058	
<i>Best Available Control Technology</i>				
I.C. Engine – Stationary, non emergency (<2,064 hp)	0.15	0.60		0.15
I.C. Engine, (landfill gas)	0.60	2.50		0.80

1. Fueled with Natural Gas

Note that there is an NAAQS limit for NO₂, not NO_x. NO_x is a shorthand expression for the sum of nitric oxide (NO) and nitrogen dioxide (NO₂). Many Air Districts control emissions of NO_x via permit limits, trading programs and BACT because NO_x reacts with volatile organic compounds (VOC) in the presence of sunlight to form O₃ (urban “smog”), which is an NAAQS pollutant. VOC is also known as NMHC (non-methane hydrocarbon), ROG (reactive organic gases), TGNMO (total gaseous non-methane organics), and others. Capstone’s measurement of THC (total hydrocarbons) includes VOC and methane, and is therefore a more conservative measure of hydrocarbon emissions than is VOC.

Most emissions sources will require some form of after burn treatment of exhaust gases in order to achieve the low emissions required by the regulations. The Capstone

MicroTurbine uses very clean combustion technology to achieve low emissions without the aid of such devices.

7.3 Mobile Applications

The EPA is authorized to regulate emissions from mobile sources in all states except California where the California Air Resources Board regulates emissions.

The EPA regulates mobile sources within 2 broad categories; heavy-duty vehicles (which includes the engines for Urban Buses) and passenger vehicles. One of the applications of the Capstone MicroTurbine is as a low emissions on board battery charger in electric buses (this application is generally referred to as a Hybrid Electric Vehicle or HEV). In this application, the EPA under the heavy-duty category could potentially regulate the emissions of the Capstone MicroTurbine. While regulations have been established for heavy-duty diesel engines in mobile applications, the EPA has not established regulations that apply to MicroTurbines at this time. Capstone has, however, undertaken its own assessment of the emissions of the Capstone MicroTurbine in HEV applications. The following table compares the emissions of the Capstone MicroTurbine with the heavy-duty diesel engine regulations.

Table 5. Mobile emissions performance and regulations (g/hp-hr)

<u>Pollutant</u>	<u>Capstone HEV Natural Gas¹</u>	<u>EPA Urban Bus 1999</u>	<u>EPA Urban Bus 2004</u>	<u>California Urban Bus 2000/5⁽²⁾</u>
NOx	0.42	4.00	2.00 ³	2.00
CO	0.75	15.50	15.50	15.50
Non-methane hydrocarbons	0.04	1.30	0.50	1.20
NOx + Non-methane hydrocarbons	0.46	5.30 ³	2.50	3.20 ³
Particulates	-	0.05	0.05	0.03/0.01

(1) The emissions tests undertaken on the Capstone MicroTurbine model 330 in an HEV application used procedures and power requirements adopted from the EPA engine-dyno test for HD Otto-cycle natural gas engines

- (2) California regulations for 2000 – 2005 reflect the September 1999 CARB Proposal for Urban Bus Engine Standards “Incentive Path”.
- (3) These are derived figures. The EPA 1999 and California regulations address NOx and NMHCs separately, while the EPA 2004 standard combines NOx and NMHCs.

The Capstone MicroTurbine offers significant improvements over the regulatory threshold for heavy duty vehicular applications.

8. Emissions Measurement and Testing

Emissions measurements are taken using Capstone’s Horiba Model 1650 MicroBench. During emissions testing, a gaseous sample is continuously extracted from the exhaust duct and transported to the analyzer console through hoses, which are heated above the dewpoint of water. The sample is split between the THC analyzer, which receives the sample hot without water knockout, and the remaining analyzers, which receive gas, which has been dried and cooled in a refrigeration bath. This equipment is state-of-the-art for emissions testing from stationary sources, and is referred to as a continuous emissions monitoring system or CEMS. Capstone’s test equipment and sampling procedures comply with applicable US Environmental Protection Agency and local air district regulations.²

There are currently no specific regulations regarding the emissions test procedure for small gas turbines. The test procedure that we have chosen is based on the procedure specified for emissions of new and in-use non-road compression ignited engines greater than 37 kW³.

² These are specified in Title 40 CFR 60, Appendix A (EPA Method 3A, EPA Method 7E, EPA Method 25A, Method 205) and SCAQMD Method 100.1.

³ The number of engines sampled will correspond to the schedules specified in Title 40 CFR 89, Appendix A to Subpart F. This could entail a minimum of three engine tests or a maximum of 60 engine tests depending on the pass/failure rate and the total engine production rate. This regulation does not require a 100% success rate

9. Emissions Corrections

Emissions levels are corrected using the following methods. The reported emissions levels are corrected for ambient concentrations of NO_x, CO or THC's sometimes found in the test cell. The levels are also corrected to 15% O₂ (typical measurement for gas turbines) using the following formula.

Carbon Monoxide (CO):

$$CO_{corrected} = (CO_{exhaust} - CO_{ambient} - 0.088 THC_{ambient}) \left(\frac{20.9 - 15}{20.9 - O_{2\text{ exhaust}}} \right)$$

Total Hydrocarbons (THC): The reported value will be the maximum of:

$$THC_{corrected} = (THC_{exhaust} - THC_{ambient}) \left(\frac{20.9 - 15}{20.9 - O_{2\text{ exhaust}}} \right)$$

or 0.0

Oxides of Nitrogen (NO_x):

$$NO_{x\text{ corrected}} = (NO_{x\text{ exhaust}} - NO_{x\text{ ambient}}) \left(\frac{20.9 - 15}{20.9 - O_{2\text{ exhaust}}} \right) (\text{ambient correction factor})$$

The ambient correction factor is obtained from CFR 60 Part 40 Subpart GG Paragraph 335. It is also contained in ES-97-01-0091.

GLOSSARY OF TERMS

<u>Abbreviation</u>	<u>Definition</u>
AFR	Air-Fuel Ratio
BACT	Best Available Control Technology
Btu	British Thermal Unit
CA	California
CARB	California Air Resources Board
CEMS	Continuous Emissions Monitoring System
CO	Carbon Monoxide
CO2	Carbon Dioxide
ECAR	East Central Area Reliability Coordination Agreement
EPA	Environmental Protection Agency
ERCOT	Electricity Reliability Council of Texas
g	gram
HP, hp	Horse Power
hp-hr	Horse Power Hour
IC	Internal Combustion
HEV	Hybrid Electric Vehicle
kW	Kilowatt
kWh	Kilowatt hour
LAER	Lowest Achievable Emissions Rate
lb	Pounds
MAAC	Mid Atlantic Area Council
MACT	Maximum Achievable Control Technology
MAIN	Mid America Interconnected Network, Inc
MW	Megawatt
NAAQS	National Ambient Air Quality Standards

NG	Natural Gas
NMHC	Non Methane Hydrocarbons
NO	Nitric Oxide
NO ₂	Nitrogen Dioxide
NO _x	The sum of NO and NO ₂
NPCC	Northeast Power Coordinating Council
NSPS	New Source Performance Standard
NSR	New Source Review
O ₂	Oxygen
O ₃	Ozone
OEM	Original Equipment Manufacturer
PM10	Particulate Matter less than 10 microns
ppm	Parts per million
PSD	Prevention of Significant Deterioration
RACT	Reasonably Available Control Technology
RECLAIM	Regional Clean Air Incentives Market
ROG	Reactive Organic Gases
SCAQMD	South Coast Air Quality Management District
SERC	Southeastern Electric Reliability Council
SIP	State Implementation Plan
SO ₂	Sulfur Dioxide
TGNMO	Total Gaseous Non-methane Hydrocarbon
THC	Total Hydrocarbons
VOC	Volatile Organic Compounds
WSCC	Western System Coordinating Council